

Town of Sahuarita

**AMENDMENTS TO THE
INTERNATIONAL ENERGY CONSERVATION CODE
2006 EDITION**

The following provisions of the International Energy Conservation Code, 2006 Edition, as published by the International Code Council, Inc. are hereby revised as follows:

Section 101.1 *Revise as follows:*

Insert "The Town of Sahuarita" as the jurisdiction.

Section 102.2 *Revise as follows:*

After the first sentence, add "The insulation shall be installed with no gaps, no voids, no compression and no air intrusion and in complete contact with the structure's air barrier."

Section 503.2.7.1.1 Duct construction. *Add the following at the end of the paragraph: "All low pressure ducts shall be leak tested in accordance with this standard. The tested rate of air leakage is not to exceed 3% of conditioned floor area in CFM at 25 Pascals (0.1 inches WC) prior to drywall and air handling equipment installation. A representative of the developer and/or builder will perform a field inspection and leakage test of the ductwork before drywall installation. The field representative will certify successful completion of this test.*

Section 504.6 Hot water system controls. *Revise as follows:*

Change "to be conveniently turned off automatically or manually when the hot water system is not in operation." to read: "to be turned off automatically."

Section 505.6.2 Exterior lighting power. *Revise as follows:*

After the first sentence, add "The lighting power densities shall not exceed the allowable limits of lighting established in the Sahuarita Outdoor Lighting Code."